IAQ Map Legend - Summer Operation

Natural ventilation: Operable windows and/or louvres should be used to manage fresh air, balancing thermal comfort and ventilation.

Evaporative cooler: will provide full fresh air when operating in either cooling or fan only mode. At least one window should be open.

Mechanical ventilation: Fresh air is introduced by the heating, ventilation and air conditioning system when in operation. Windows can remain closed and no action is required by the school.

Note. White spaces are to be used in accordance with COVID-19 requirements and current health advice.

ISSUE	AMENDMENT	DRAWN	VER'D	APP'D	DATE

SCALE 1:500

DATE JAN 2016

DRAWING SHEET SIZE = A3

ACT Government Education and Training

PROJECT

CALWELL PRIMARY SCHOOL
INFRASTUCTURE & CAPITAL WORKS
SCHOOL LAYOUT PLAN